



### TEST REPORT

DATE: 07-12-2023

Page 1 of 1

TEST NUMBER: 0297874

<b>CLIENT</b>	Palziv North America
---------------	----------------------

<b>TEST METHOD CONDUCTED</b>	ASTM E96 Standard Test Method for Water Vapor Transmission of Materials: Water Method
------------------------------	---



DESCRIPTION OF TEST SAMPLE	
<b>IDENTIFICATION</b>	HQ Living Carpet Cushion - 7/16" Green

#### GENERAL PRINCIPLE

These test methods cover the determination of water vapor transmission of materials through which the passage of water vapor may be of importance, such as paper, plastic films, other sheet materials, fiberboards, gypsum and plaster products, wood products, and plastics.

#### TEST CONDITIONS:

<b>TEMPERATURE</b>	70° F
<b>RELATIVE HUMIDITY</b>	50%
<b>CUP</b>	Glass permeation cell 3.0 inch

#### TEST RESULTS

<b>WATER VAPOR EMISSION</b>	0.105 grains/m <sup>2</sup> /24 hrs (0.015 lbs/1000 ft/24 hrs)
<b>PERMEANCE</b>	0.068 grains/hr/ft <sup>2</sup> /Hg

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.